



Certificate No. 201500887

## **CERTIFICATE of PERFORMANCE ACCREDITATION**

**Applicant** : KIM HYOUNG SOO

**Company** : ASUNG CLEAN FLOW TECH CO.,LTD.

**Address** : 563-12 Bukok-Ri, Songak-Meun, Dangjin-Gun, Chungcheongnam-Do, Korea

This is to certify that the following item has been approved in accordance with the provisions of Article 39 (1) of Installation, Maintenance, And Safety Control Of Fire-Fighting Systems Act and Article 17 (1), Article 18 (2) of Regulation On Quality Control, Etc. Of Fire-Fighting Appliances.

- |                      |   |
|----------------------|---|
| 1. Item              | Synthetic Resin Pipe for Fire Protection Service  |
| 2. Type              | Indoor Pipe(Type I ), Nominal Size 20, 25, 32, 40, 50, 65, 80, 100, 125, 150<br>Maximum Allowable Pressure 1.2 MPa, |
| 3. Type Approval No. | 합수15-6  |
| 4. Limitation        | -   |

\_\_\_\_\_  
President

Date : 21 Sep. 2015

Korea Fire Institute

