

Our Ref: HL/M1402072
Test Report: M105734

14th August 2014

WRAS[®]

Water Regulations Advisory Scheme

Zhejiang Weixing New Building Materials Co. Ltd.
No. 229 Middle Baiye Road,
Linhai City,
Zhejiang,
China

WATER REGULATIONS ADVISORY SCHEME (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS 6920-1:2000 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYETHYLENE – COMPONENTS

5240

Weixing HDPE Pipe. Black coloured, extruded HDPE pipe with blue coloured stripes on the exterior. For use with water up to 23°C.

APPROVAL NUMBER: 1407538


APPROVAL HOLDER: ZHEJIANG WEIXING NEW BUILDING MATERIALS CO. LTD.

The Scheme reserves the right to review approval. This approval is valid between July 2014 and July 2019.

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully



Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme